Green Data Centers and Sustainable Computing: Advancing Energy-Efficient Infrastructure for Carbon Reduction and Environmental Sustainability in India

Aadya Goel

Independent Researcher

DOI: https://doi.org/10.51244/IJRSI.2026.1311000025

Received: 26 October 2026; Accepted: 01 November 2026; Published: 20 November 2026

ABSTRACT

The exponential growth of artificial intelligence (AI) and advanced computational workloads has catalyzed an unprecedented surge in electricity demand for data centers, fundamentally challenging India's climate targets, municipal resource security, and macro-grid stability. As hyperscale facilities and enterprise data centers pivot to accommodate massive computational requirements, driven by the transition from general-purpose processing to highly dense AI infrastructure, the Indian digital economy faces critical bottlenecks regarding energy generation, thermal management, and lifecycle carbon emissions. This comprehensive report provides an in-depth analysis of sustainable computing paradigms within the Indian context, synthesizing the latest developments in data center infrastructure, standardized sustainability metrics, and grid-interactive technologies. The analysis explores the necessary transition from traditional air-cooled environments to direct-to-chip and immersion cooling technologies, highlighting the physical and regulatory constraints shaping thermal management in India's diverse and often harsh climates. Furthermore, the report delineates the critical distinction between operational carbon and embodied carbon, demonstrating how hardware lifecycle economics impact India's sovereign AI ambitions and overall Scope 3 emissions. Through the lens of carbon-aware computing, the analysis explores how spatial and temporal workload shifting, coupled with Battery Energy Storage Systems (BESS), can transform data centers into active grid-stabilizing assets. The study rigorously evaluates India's national policies, utilizing guidelines from the Central Electricity Authority (CEA) and NITI Aayog as a paradigm for integrating data center growth with digital sovereignty and the Viksit Bharat 2047 vision. The findings underscore the absolute necessity of a holistic, lifecycle-aware approach to data center design that integrates hardware procurement, dynamic resource scheduling, and macro-grid synchronization to achieve genuine environmental sustainability in the AI era.

Keywords: Sustainable computing, artificial intelligence, data centers, thermal management, carbon-aware computing, embodied carbon, grid stability, digital sovereignty, India

INTRODUCTION

The global transition toward an electricity-based economy is increasingly dominated by the rapid proliferation of data centers and the widespread integration of artificial intelligence into commercial, industrial, and scientific sectors. Within this global shift, India has emerged as a primary hub for digital infrastructure expansion. India's data center industry has grown more than fourfold in five years, expanding from 375 megawatts (MW) of installed capacity in 2020 to approximately 1,575 MW in 2026. Historically, data center electricity consumption experienced moderate and predictable growth. However, the advent of generative AI, large language models, and continuous machine learning pipelines has aggressively accelerated this trajectory. The Central Electricity Authority (CEA) under the Ministry of Power projects that data centers could require between 13.6 and 17.0 gigawatts (GW) of power capacity by 2031 to 2032, with AI specific data centers potentially putting an additional load of 26.3 GW on the national grid.

This dramatic escalation in power demand is primarily driven by the physical infrastructure required for AI training and inference. The computational intensity of frontier AI models necessitates the continuous operation

ISSN No. 2321-2705 | DOI: 10.51244/IJRSI |Volume XIII Issue XI November 2026

of thousands of high-performance accelerators over extended periods. India's own sovereign AI program, the IndiaAI Mission, illustrates this scale perfectly. Backed by a $1.25 billion investment, the mission built a national shared compute pool that crossed 34,000 GPUs by mid-2025 and is targeting 100,000 GPUs by the end of 2026. A single query processed by an advanced generative AI model consumes approximately 2.9 watt-hours of electricity, nearly ten times the 0.3 watt-hours required for a conventional search engine query. Consequently, S&P Global Commodity Insights estimates that Indian data centers consumed approximately 13 terawatt-hours (TWh) of electricity in 2024, representing 0.8% of India's total electricity demand, a figure projected to scale dramatically. If current trends hold, the projected 57 TWh required by 2030 would be equivalent to more than 3.5 times the current annual electricity consumption of a major tech hub like Bengaluru.

While the macro-level impact on global and national electricity demand is significant, the localized effects of data center proliferation are acute and increasingly problematic for Indian municipal planning. Growth is geographically concentrated, with Mumbai and Chennai accounting for roughly three-fifths of operational capacity, heavily straining local grids that are least equipped to absorb massive new loads. In comparative terms, India's entire data center fleet today has a combined power capacity roughly equal to 27% of the record 5.87 GW peak load that Bengaluru draws on a hot summer afternoon. This localized strain has prompted intense scrutiny from utility providers, environmental regulators, and local residents. Opposition has grown sharply concentrated on water and pollution concerns at flagship projects in Visakhapatnam and Balkum in Thane, where local communities are protesting the immense water consumption and diesel generator emissions associated with gigawatt-scale technology parks. Consequently, the Indian digital infrastructure industry is undergoing a fundamental transformation, transitioning from a singular focus on computational throughput to a complex optimization problem that must dynamically balance performance, grid stability, water stewardship, and total carbon footprint.

Methodology and Procedure

To systematically evaluate the multifaceted impacts of data center operations and the efficacy of sustainable computing interventions in the Indian context, this analysis employs a multi-dimensional research methodology encompassing facility-level performance tracking, lifecycle carbon accounting, and macro-grid synchronization modeling.

The procedure began with an exhaustive review of statutory reports, grid adequacy models, and policy frameworks published by Indian regulatory bodies. Primary data sources include the Central Electricity Authority (CEA) National Generation Adequacy Plan, NITI Aayog sectoral insights on power and net-zero goals, and Ministry of Power parliamentary disclosures regarding AI infrastructure loads. This macro-level data was synthesized with global technological metrics to contextualize how international hardware trends impact the Indian power grid.

At the facility and equipment level, the primary evaluative standard utilized throughout this report is the ISO/IEC 30134 series, which provides a comprehensive suite of Key Performance Indicators for data center resource efficiency. This framework deliberately moves beyond traditional energy efficiency metrics to incorporate resource circularity, water usage effectiveness, and carbon intensity. Computational efficiency at the server level is assessed using standardized methodologies such as the Standard Performance Evaluation Corporation Server Efficiency Rating Tool (SPEC SERT). SPEC SERT measures energy proportionality across variable load levels, allowing for accurate modeling of power draw in real-world scenarios where servers are rarely fully utilized.

Furthermore, the analytical procedure incorporates Life Cycle Assessment (LCA) methodologies to quantify the environmental impacts of hardware across its entire lifespan. This approach critically differentiates between operational carbon, which stems from the electricity consumed on the Indian grid, and embodied carbon, which includes emissions associated with the global manufacturing and supply chain of imported semiconductors. Finally, the framework evaluates grid integration by analyzing the technical requirements for Fast Frequency Response (FFR) utilizing Battery Energy Storage Systems (BESS) according to IEEE 2800-2022 standards and CEA grid requirements.

DISCUSSION AND INTERPRETATION

The Escalating Power Density Crisis and Hardware Evolution

The physical architecture of the modern Indian data center is being radically disrupted by the extreme power density of next-generation AI accelerators. Historically, data center racks operated at an average power density of 7 to 9 kilowatts (kW), allowing for standard raised-floor architectures and ambient air cooling. However, the integration of specialized silicon for deep learning has obliterated these historical baselines. By 2026, the modal rack density across general enterprise data centers surpassed 11 kW, while the overall average reached 27 kW. More critically, racks purpose-built for high-performance computing and AI training are now engineered to support loads between 80 kW and 120 kW, with test units for future iterations being engineered for an astonishing 600 kW per rack by 2027.

This explosion in power density is a direct consequence of the thermal design power (TDP) of contemporary GPUs imported for Indian AI hubs. While previous generation chips like the NVIDIA H100 consumed approximately 700 watts, modern reticle-limit devices have pushed silicon to its thermal edge. The NVIDIA Blackwell B200 architecture utilizes a multi-die GPU design that requires 1000 watts in a standard air-cooled configuration, peaking at 1200 watts under direct liquid cooling. The forthcoming Blackwell Ultra B300 pushes this envelope further to 1400 watts per chip.

When aggregated into multi-GPU server nodes, such as a typical eight-GPU tray where eight B200s draw 9.6 kW for the silicon alone, the power requirements scale exponentially. In rack-scale architectures like the NVIDIA GB200 NVL72, which integrates 72 Blackwell GPUs and 36 Grace CPUs acting as a single computing unit, the continuous power draw reaches approximately 120 kW. This density crisis dictates that capacity in tech parks across Mumbai and Visakhapatnam can no longer be evaluated merely by square footage, but must be strictly defined by megawatt capacity and thermal dissipation limits. The inability of traditional air-cooling infrastructure to manage heat fluxes beyond 30 to 40 kW per rack renders legacy facilities obsolete for frontier AI deployment without massive retrofits.

Thermal Management and Water Security in India

As power densities rise past the physical limitations of forced-air convection, operators are forced to rapidly transition away from traditional Computer Room Air Conditioning (CRAC) and evaporative cooling. A primary indicator of data center efficiency is Power Usage Effectiveness (PUE), representing the ratio of total facility power to the power delivered exclusively to IT equipment. Despite significant industry focus, the global average PUE has stagnated at approximately 1.54 to 1.56. This plateau indicates that legacy air-cooled facilities still waste up to 40% of their total electricity consumption on thermal management, a highly problematic statistic given India's hot climate.

To breach this plateau, operators are adopting Direct Liquid Cooling (DLC) and immersion cooling technologies. DLC utilizes closed-loop cold plates directly attached to high-heat components, capturing up to 98% of the generated heat and lowering facility PUE to the 1.10 to 1.20 range. Immersion cooling takes this concept further by submerging entire server chassis directly into dielectric fluids. Single-phase immersion utilizes a pumped dielectric liquid to transfer sensible heat. Two-phase immersion cooling leverages the latent heat of vaporization using engineered fluorinated fluids to manage extreme instantaneous heat fluxes, achieving PUE values as low as 1.02 to 1.05.

However, two-phase immersion has encountered a catastrophic regulatory bottleneck globally. The fluorinated fluids required belong to a class of chemicals known as per- and polyfluoroalkyl substances (PFAS). Due to their extreme environmental persistence and toxicity, chemical manufacturers like 3M announced the total discontinuation of their Novec product lines by 2025. This forces operators to pivot back to single-phase immersion and DLC, fundamentally altering the trajectory of high-density thermal management.

In the Indian context, thermal management directly impacts regional water security. Traditional evaporative cooling towers consume millions of liters of potable water. Applying global metrics to India's current 1.575 GW

ISSN No. 2321-2705 | DOI: 10.51244/IJRSI |Volume XIII Issue XI November 2026

capacity implies that data centers nationally draw on the order of 12 to 13 billion liters of water annually. This volume represents roughly 15% of the total water a city like Mysuru supplies its residents in an entire year. In Visakhapatnam, where a 1 GW tech hub is under construction, local activist groups have launched protests, citing that the city already experiences a 70 million liter daily water shortfall. This localized water stress forces hyperscalers to commit to closed-loop zero-water cooling systems, which unfortunately operate at lower electrical efficiencies during India's high ambient temperature summers, demonstrating a zero-sum thermodynamic tradeoff between water conservation and electrical efficiency.

Standardized Metrics and Operational Efficiency

The tension between energy efficiency and water conservation illustrates the inadequacy of relying solely on PUE as a proxy for sustainability. The ISO/IEC 30134 series establishes a broader taxonomy of data center metrics, standardizing the language of environmental reporting. Metrics such as Carbon Usage Effectiveness (CUE) and Water Usage Effectiveness (WUE) enable operators to quantify the complex tradeoffs inherent in facility design. For example, deploying a closed-loop DLC system utilizing dry coolers may slightly elevate PUE compared to open-loop evaporative cooling, but it drives WUE down to near zero, satisfying municipal water constraints in drought-prone Indian states. EDE or Electronics Disposal Efficiency also measures the lifecycle end-stage, pushing the industry toward a circular economy model by tracking the responsible disposal and recycling of decommissioned servers.

At the equipment level, the SPEC Server Efficiency Rating Tool (SERT) generates standardized, multi-dimensional profiles of server energy proportionality. Because servers rarely operate at 100% utilization, SERT evaluates power consumption across various active load levels. This granularity allows Indian operators to optimize hardware procurement for specific application demands, enabling the deployment of servers that maintain high computational efficiency even during periods of low traffic.

The Semiconductor Paradox: Embodied Carbon

While the Indian government and private operators aggressively pursue renewable energy to mitigate operational emissions (Scope 2), the environmental burden of computing is shifting upstream to the manufacturing phase, known as embodied carbon (Scope 3). Scope 3 emissions account for the greenhouse gases generated during raw material extraction, component manufacturing, and infrastructure construction.

To increase computational efficiency, data centers deploy the latest specialized silicon. However, manufacturing these cutting-edge nodes requires Extreme Ultraviolet (EUV) lithography. EUV lithography is immensely energy intensive, and the fabrication process utilizes fluorinated greenhouse gases with high global warming potentials. Consequently, the electricity consumed by major semiconductor foundries is now on par with the energy consumption of entire hyperscale data center fleets.

Therefore, while a new generation of AI hardware reduces the operational electricity demand required for a specific workload in an Indian data center, the embodied carbon cost of manufacturing that imported hardware is astronomical. This sunk carbon fallacy dictates that extending server lifespans, maximizing hardware utilization, and prioritizing hardware reuse are mathematically imperative to amortize the embodied carbon of advanced silicon. The industry is pushing for enhanced transparency through Environmental Product Declarations (EPDs), which act as verified nutrition labels detailing the exact embodied carbon of data center components. Manufacturers like Dell Technologies increasingly mandate that their suppliers align with Science Based Targets initiative standards, pushing absolute Scope 3 GHG reductions deep into the supply chain.

Macro-Grid Synchronization and Fast Frequency Response in India

Sustainable computing must seamlessly integrate with India's rapidly evolving macro-grid. India has emerged as the world's fourth-largest renewable energy market, adding a record 52.5 GW of new generation capacity in FY 2025 to 2026, with solar PV dominating the landscape at over 140 GW. However, integrating gigawatt-scale AI data centers into a grid heavily reliant on variable renewable energy poses immense stability challenges.

ISSN No. 2321-2705 | DOI: 10.51244/IJRSI |Volume XIII Issue XI November 2026

Carbon-aware computing offers a software-level intervention by modulating computational workloads based on the real-time carbon intensity of the local power grid. Because the carbon footprint of electricity fluctuates hourly based on solar and wind availability, intelligent scheduling can drastically reduce operational emissions. Temporal shifting involves delaying tolerant workloads until local grid carbon intensity is low, while spatial shifting routes computational tasks across geographically distributed data centers to regions where renewable energy is abundant.

Furthermore, Indian data centers are uniquely positioned to become active, dispatchable grid-stabilizing assets. The rapid integration of converter-interfaced renewable energy sources has fundamentally reduced the mechanical inertia of the grid, making it vulnerable to rapid frequency fluctuations. Modern grid codes, such as IEEE 2800-2022, mandate that inverter-based resources provide active frequency support. Data centers, equipped with massive uninterruptible power supplies (UPS) and Battery Energy Storage Systems (BESS), can provide Fast Frequency Response (FFR). By coordinating BESS discharge with the immediate, temporary throttling of flexible IT workloads, data centers can inject vital active power in under one second to arrest a sudden drop in grid frequency. The CEA anticipates India will require 174 GW of storage by 2035 to 2036, marking a shift from storage as a niche technology to a core grid asset. Data centers integrating advanced BESS can directly support this national mandate.

Geopolitical and Regional Policy Frameworks: The Indian Paradigm

The tension between data center expansion and municipal utility protection is forcing the Indian government to enact comprehensive regulatory frameworks. The Central Electricity Authority has embedded advanced modeling into national planning, signaling a structural transformation where non-fossil capacity will account for 70% of total installed capacity by 2035 to 2036. However, this clean energy transition must balance the immense power demands of data centers with residential and industrial electrification.

To prevent the crowding out of standard industrial growth, authorities are implementing stricter oversight mechanisms. The rapid growth of AI data centers is creating new sources of electricity demand that many municipalities were not designed to regulate. While data center growth brings economic development, job creation, and strategic value for India's digital sovereignty, communities are demanding transparency regarding resource allocation. The reliance on coal remains critical for medium-term reliability to anchor system stability during non-solar hours. Consequently, the Indian paradigm illustrates that green data centers must be deeply integrated with national generation adequacy plans, balancing AI advancement with the protection of the grid and local resources.

Next-Generation Computing: Neuromorphic and Photonic Architectures

As the digital computing paradigm approaches fundamental thermodynamic limits, deep research into non-von Neumann architectures presents a radical pathway toward sustainable AI. Conventional architectures suffer heavily from the von Neumann bottleneck, wherein immense energy is continuously expended simply moving data between the processor and memory components.

Neuromorphic computing circumvents this bottleneck by taking architectural inspiration directly from the human brain, utilizing physical artificial neurons to perform massively parallel, event-driven processing. Through the use of Spiking Neural Networks (SNNs), neuromorphic processors communicate via discrete spike events rather than continuous floating-point operations. Because energy is consumed only when a neuron actively fires, these systems exhibit extraordinary energy proportionality. Advanced edge-AI frameworks have demonstrated energy efficiencies of 847 GOp/s/W, reducing overall energy consumption by up to 67% while maintaining classification accuracy.

Simultaneously, photonic computing leverages integrated optical circuits to process information using light rather than electrons. Photonic Artificial Neural Networks offer sub-nanosecond latencies and negligible heat dissipation, completely bypassing the resistive heating that plagues copper interconnects. Recent innovations integrating on-chip capacitive analog memory directly alongside photonic computing units have successfully mitigated data movement penalties, yielding power savings exceeding 26-fold compared to conventional

architectures. Integrating these next-generation processors is vital for decoupling India's sovereign AI ambitions from exponential energy and cooling demands.

Limitations

Despite the comprehensive nature of the sustainable computing strategies outlined, significant limitations impede their immediate realization in India. First, the application of Life Cycle Assessment (LCA) and the rigorous tracking of Scope 3 emissions are severely constrained by a lack of supply chain transparency. Tier-2 and Tier-3 suppliers often lack the capability to produce rigorous Environmental Product Declarations (EPDs), forcing LCAs to rely on generalized databases that struggle to accurately reflect the semiconductor manufacturing landscape.

Second, the physical limits of thermal management present absolute barriers, especially in India's diverse climate zones. While Direct Liquid Cooling effectively manages high-TDP silicon at the chip level, it transfers the thermal burden to the facility's secondary water loops, which still ultimately require heat rejection into the atmosphere. Municipal bans and community protests regarding potable water consumption force reliance on dry coolers, which operate at lower efficiencies during high-ambient-temperature Indian summers, creating an unavoidable tradeoff between water conservation and electrical efficiency.

Finally, the efficacy of carbon-aware spatial workload shifting is strictly bounded by India's transmission constraints. The IEEFA estimates that over 50 gigawatts of renewable energy stood stranded as of mid-2025 for want of transmission capacity. Data privacy regulations also mandate that sensitive data remains within specific geopolitical boundaries, nullifying the potential for cross-border spatial optimization and trapping workloads in grids with potentially high carbon intensities.

Suggestions for Future Study

To overcome the aforementioned limitations, future research should prioritize several interdisciplinary domains tailored to the Indian context. First, urgent materials science research is required to synthesize zero-Global Warming Potential dielectric fluids that can support immersion cooling in tropical climates without posing biological toxicity, replacing discontinued PFAS chemicals.

Second, the development of dynamic real-time Life Cycle Assessment simulators must be accelerated. Expanding frameworks to integrate live telemetry from global semiconductor foundries would empower AI scheduling algorithms to make real-time calculations regarding the sunk carbon fallacy, optimizing the exact mathematical point at which upgrading hardware yields a net environmental benefit for Indian tech hubs.

Third, research into macro-grid integration should focus on multi-agent reinforcement learning algorithms capable of orchestrating data center BESS, UPS, and server power-capping mechanisms in real-time. These algorithms must co-optimize for AI workload service-level agreements and Fast Frequency Response signals from Indian grid operators like the CEA, seamlessly transforming gigawatt-scale data centers into autonomous virtual power plants.

Lastly, transitioning the AI ecosystem to leverage the extreme energy efficiency of Spiking Neural Networks and photonic interconnects will require the invention of novel hardware-aware training algorithms that embrace sparsity, fundamentally reducing the energy footprint of future AI deployments.

CONCLUSION

The intersection of artificial intelligence, high-performance computing, and global energy infrastructure represents one of the most critical sustainability challenges for India's digital future. The aggressive trajectory of data center expansion, fueled by specialized silicon demanding upwards of 1200 watts per chip and driving India's facility consumption toward a projected 17 GW to 26 GW by 2031, renders historical efficiency paradigms entirely obsolete. The industry can no longer rely on incremental improvements to Power Usage Effectiveness or traditional air-cooling methodologies to mitigate its environmental footprint, especially amid

severe local water constraints and high ambient temperatures.

Achieving genuine environmental sustainability necessitates a radical approach aligned with India's Viksit Bharat 2047 goals and Net Zero by 2070 commitments. At the micro-level, the transition to Direct Liquid Cooling and the deep exploration of neuromorphic and photonic architectures represent vital steps toward decoupling computational scale from immense thermal dissipation. At the macro-level, the transition from simple operational carbon mitigation to rigorous Scope 3 supply-chain accounting is imperative. The immense embodied carbon generated by advanced semiconductor fabrication dictates that hardware procurement and lifespan extension are now equally as critical as facility power efficiency.

Ultimately, the future of sustainable computing lies in the synergistic integration of the data center with India's national power grid. By deploying carbon-aware workload scheduling, prioritizing Environmental Product Declarations, and utilizing vast distributed battery reserves to provide Fast Frequency Response, data centers possess the unique capability to underwrite and stabilize the deployment of India's expanding renewable energy portfolio. Transforming data centers from static utility loads into dynamic grid-stabilizing assets offers the most viable pathway to scaling the computational demands of the AI era without compromising India's environmental sovereignty or municipal resilience.

REFERENCES

1. AKCP. (2022, February 16). Introduction to international data center standards. https://www.akcp.com/2022/02/16/introduction-to-international-data-center-standards/
2. Alliance Chemical. (2026). Two-phase vs. single-phase immersion cooling fluids (2026). https://alliancechemical.com/blogs/articles/two-phase-vs-single-phase-immersion-cooling-fluid-selection
3. Aravolta. (n.d.). Environmental product declarations (EPDs) for data centers. https://www.aravolta.com/energy-solutions/environmental-product-declaration
4. ASTESJ. (n.d.). An overview of data center metrics and a novel approach to data center efficiency. https://www.astesj.com/?sdm_process_download=1&download_id=4029
5. Bizo, D., Donnellan, D., Lawrence, A., O'Brien, J., Davis, J., Smolaks, M., Williams-George, J., & Weinschenk, R. (2024). Uptime Institute global data center survey 2024. Uptime Institute.
6. Brookings Institution. (n.d.). Global energy demands within the AI regulatory landscape. https://www.brookings.edu/articles/global-energy-demands-within-the-ai-regulatory-landscape/
7. Carbon Connect. (2024). Carbon Connect: An ecosystem for sustainable computing. arXiv. https://arxiv.org/html/2405.13858
8. Central Electricity Authority. (2026). National generation adequacy plan (2026–27 to 2035–36). Ministry of Power, Government of India. https://cea.nic.in/notification/national-generation-adequacy-plan-2026-27-to-2035-36/
9. Coordinated fast frequency response from electric vehicles, data centers, and battery energy storage systems. (n.d.). ResearchGate. https://www.researchgate.net/publication/398765600_Coordinated_Fast_Frequency_Response_from_Electric_Vehicles_Data_Centers_and_Battery_Energy_Storage_Systems
10. The case for energy-aware semiconductor lithography. (n.d.). https://www.chetanpatil.in/the-case-for-energy-aware-semiconductor-lithography/
11. Data Centers List. (n.d.). How much power does a data center use? https://www.datacenterslist.com/stats/power-consumption
12. Data Center Knowledge. (2026). AI drives data center uncertainty in Uptime's 2026 survey. https://www.datacenterknowledge.com/ai-data-centers/ai-drives-data-center-uncertainty-in-uptime-s-2026-survey
13. Data Center Knowledge. (n.d.). Data center industry calls for environmental "nutrition labels" to cut carbon emissions. https://www.datacenterknowledge.com/green-materials/data-center-industry-calls-for-environmental-nutrition-labels-to-cut-carbon-emissions
14. Dell Technologies. (n.d.). Climate action. https://www.dell.com/en-us/lp/dt/climate-action
15. Dell Technologies. (n.d.). Dell. Greenplaces. https://greenplaces.com/buyer-mandates/dell

16. Fluorinated Chemicals. (n.d.). Single-phase vs. two-phase immersion cooling. https://www.fluorined-chemicals.com/info/single-phase-vs-two-phase-immersion-cooling-103109588.html
17. Gateway House. (n.d.). The missing pillar of India's sovereign AI. https://www.gatewayhouse.in/the-missing-pillar-of-indias-sovereign-ai/
18. GreenFuel Journal. (n.d.). AI data center power and the new energy economy: Why tech giants are rebuilding the baseload energy. https://www.greenfueljournal.com/post/ai-data-center-power-and-the-new-energy-economy-why-tech-giants-are-rebuilding-the-baseload-energy
19. Gupta, U., et al. (2022). Architectural CO2 footprint tool (ACT): Carbon characterization and sustainability-driven early design space exploration. IEEE/ACM.
20. Hans, K., Zhao, K., & Lee, S. (2026). CarbonSim: A lifecycle-aware framework for evaluating carbon tradeoffs in hardware upgrade decisions. arXiv. https://arxiv.org/html/2606.06438
21. HuntMS: A framework for microservice geo-distribution for carbon. (2026). arXiv. https://arxiv.org/pdf/2603.10768
22. International Energy Agency. (2025). Electricity 2025. IEA. https://www.iea.org/reports/electricity-2025/demand
23. International Energy Agency. (2026). Electricity 2026. IEA. https://www.iea.org/reports/electricity-2026/demand
24. International Energy Agency. (2026). Electricity 2026: The age of electricity and global demand trends. IEA Publications.
25. IntelliSmart Infrastructure. (n.d.). Smart metering: Latest updates. https://www.intellismartinfra.in/resource-centre/sector-updates
26. Introl. (n.d.). Achieving PUE 1.09 in AI data centers. https://introl.com/blog/pue-109-google-data-center-efficiency-strategies
27. International Organization for Standardization & International Electrotechnical Commission. (2018). Information technology—Data centres—Key performance indicators—Part 1: Overview and general requirements—Amendment 1 (ISO/IEC 30134-1:2016/Amd 1:2018). https://www.iso.org/standard/72277.html
28. IJSRA. (2025). Neuromorphic computing: Bridging AI and electronics. https://ijsra.net/sites/default/files/fulltext_pdf/IJSRA-2025-1137.pdf
29. July Ventures. (2026, September 9). The AI data center conundrum. https://www.julyventures.com/blogs/the-ai-data-center-conundrum
30. KeenTel Engineering. (n.d.). BESS grid compliance: Droop control & FFR guide. https://keentelengineering.com/us-grid-code-droop-control-ffr-bess
31. Kistowski, J. von, Lange, K.-D., Arnold, J. A., Sharma, S., Pais, J., & Block, H. (2018). Measuring and benchmarking power consumption and energy efficiency. In Companion of the 2018 ACM/SPEC International Conference on Performance Engineering (pp. 57–65). ACM. https://doi.org/10.1145/3185768.3185775
32. Life-cycle emissions of AI hardware: A cradle-to-grave approach and generational trends. (2025). arXiv. https://arxiv.org/html/2502.01671
33. MGrid. (2026, February 13). Data center PUE gains stall as liquid cooling adoption hits 19%. https://mgrid.org/2026/02/13/data-center-pue-plateau-liquid-cooling-19-percent-adoption/
34. ModulEdge. (n.d.). Green data center: Design, certification & examples. https://www.moduledge.com/blog/green-data-center
35. NITI Aayog. (2026). Scenarios towards Viksit Bharat and net zero: Sectoral insights—Power (Vol. 7). Government of India. https://www.niti.gov.in/sites/default/files/2026-02/Scenarios-Towards-Viksit-Bharat-and-Net-Zero-Sectoral-Insights-Power_0.pdf
36. Neuromorphic computing for low-power artificial intelligence. (2026). arXiv. https://arxiv.org/pdf/2604.04727
37. Neuromorphic photonic computing with an electro-optic analog. (2024). arXiv. https://arxiv.org/html/2401.16515
38. Neuromorphic processing: The future of energy efficient AI. (n.d.). ResearchGate. https://www.researchgate.net/publication/400886661_Neuromorphic_Processing_The_Future_of_Energy_Efficient_AI_Computing
39. Per- and polyfluoroalkyl substances (PFAS): Guidelines and chemical phase-out tracking. (2023). U.S.

Environmental Protection Agency. https://www.epa.gov/sdwa/and-polyfluoroalkyl-substances-pfas
40. Photonic computing for neuromorphic computing: Fundamentals, devices. (2023). arXiv. https://arxiv.org/html/2311.09767
41. Power system frequency response enhancement using optimal… (2026). Preprints. https://www.preprints.org/manuscript/202601.2113
42. Power systems frequency response enhancement using optimal… (n.d.). ProQuest. https://search.proquest.com/openview/c5880869c89d67e9971fbc4a82e50887/1?pq-origsite=gscholar&cbl=2032402
43. Predicting power consumption of high-memory-bandwidth workloads. (2017). SPEC Research. https://research.spec.org/icpe_proceedings/2017/proceedings/p353.pdf
44. Predicting server power consumption from standard rating results. (2019). University of Würzburg. https://se.informatik.uni-wuerzburg.de/publications/?tx_extbibsonomycsl_publicationlist%5Baction%5D=download&tx_extbibsonomycsl_publicationlist%5Bcontroller%5D=Document&tx_extbibsonomycsl_publicationlist%5BfileName%5D=KiGrScKo2019-ICPE-PowerPrediction.pdf&tx_extbibsonomycsl_publicationlist%5BintraHash%5D=a826f3539bbe4449819b6619b1273c7a&tx_extbibsonomycsl_publicationlist%5BuserName%5D=se-group&cHash=25bde2db6fd9346e60657762f50dddbf
45. Radovanovic, A., et al. (2022). A holistic approach for designing carbon aware datacenters. Google Research. https://www.researchgate.net/publication/358143189_A_Holistic_Approach_for_Designing_Carbon_Aware_Datacenters
46. Ramboll. (n.d.). 100+ kW per rack in data centers: The evolution and… https://www.ramboll.com/en-us/insights/decarbonise-for-net-zero/100-kw-per-rack-data-centers-evolution-power-density
47. RESI India. (n.d.). India's power sector: CEA's generation adequacy plan charts a 10-year clean energy transition. https://www.resiindia.org/post/india-s-power-sector-cea-s-generation-adequacy-plan-charts-a-10-year-clean-energy-transition
48. Sustainable transition of the global semiconductor industry. (2025). Sustainability, 17(7), 3160. https://www.mdpi.com/2071-1050/17/7/3160
49. Schneider, I., Xu, H., Benecke, S., Patterson, D., Huang, K., Ranganathan, P., & Elsworth, C. (2025). Life-cycle emissions of AI hardware: A cradle-to-grave approach and generational trends. arXiv. https://arxiv.org/abs/2502.01671
50. ServNet UK. (2026). GPU rack power density 2026: 700W chips to 600kW racks. https://www.servnetuk.com/research/gpu-rack-power-density-tracker-2026
51. ServeTheHome. (n.d.). 2-phase immersion cooling halted over multi-billion-dollar health hazard lawsuits. https://www.servethehome.com/2-phase-immersion-cooling-halted-over-multi-billion-dollar-health-hazard-lawsuits/
52. Shriram Mutual Fund. (2026). Sovereign AI and India's data center infrastructure needs. Sectoral report.
53. Sustainable Internet Lab. (2025). Subsea. https://sustainableinternetlab.com/wp-content/uploads/2025/05/SF-136_FINAL-1.pdf
54. Supermicro. (2024). AI SuperCluster NVIDIA GB200 NVL72 liquid-cooling solutions. https://www.supermicro.com/manuals/brochure/Brochure-AI-SuperCluster-NVIDIA-GB200-NVL72.pdf
55. TAIROA B2B. (n.d.). Supermicro NVIDIA Blackwell architecture solutions. https://www.tairoab2b.com/storage/product/f288a5e7-64f3-4961-9573-8aa2b243cd1b.pdf
56. U.S. Environmental Protection Agency. (2023). Per- and polyfluoroalkyl substances (PFAS). https://www.epa.gov/sdwa/and-polyfluoroalkyl-substances-pfas
57. Uptime Institute. (2024). Uptime Institute global data center survey 2024. https://datacenter.uptimeinstitute.com/rs/711-RIA-145/images/2024.GlobalDataCenterSurvey.Report.pdf
58. Why PUE remains flat and what should be done about it. (n.d.). Upsite Technologies. https://www.upsite.com/blog/why-pue-remains-flat-and-what-should-be-done-about-it/
59. Energy-aware computing in the year 2026. (2026). arXiv. https://arxiv.org/html/2605.24569
60. Energy-efficient neuromorphic computing for edge AI. (2026). arXiv. https://arxiv.org/html/2602.02439

61. Equity-aware spatial-temporal workload shifting for sustainable AI data centers. (n.d.). ResearchGate. https://www.researchgate.net/publication/387189564_Equity-Aware_Spatial-Temporal_Workload_Shifting_for_Sustainable_AI_Data_Centers
62. The missing pillar of India's sovereign AI. (n.d.). Gateway House. https://www.gatewayhouse.in/the-missing-pillar-of-indias-sovereign-ai/
63. Metrics for data center embodied carbon. (n.d.). ResearchGate. https://www.researchgate.net/publication/395083223_Metrics_for_Data_Center_Embodied_Carbon
64. NVIDIA Blackwell GPU architecture: Unleashing next-generation AI. (n.d.). Weights & Biases. https://wandb.ai/onlineinference/genai-research/reports/NVIDIA-Blackwell-GPU-architecture-Unleashing-next-gen-AI-performance–VmlldzoxMjgwODI4Mw
65. Scope 3 data center emissions. (n.d.). Stream Data Centers. https://www.streamdatacenters.com/resource-library/glossary/scope-3-data-center-emissions/
66. Semiconductor Emission Explorer: Tracking greenhouse gas emissions. (n.d.). Interface. https://www.interface-eu.org/index.php/publications/semiconductor-emission-explorer
67. The sunk carbon fallacy: Rethinking carbon footprint metrics for… (2024). University of British Columbia. https://cirrus.ece.ubc.ca/papers/socc24-sunk-carbon-fallacy.pdf
68. Uptime Institute global data center survey 2024: Regional view. (2024). Uptime Institute. https://intelligence.uptimeinstitute.com/sites/default/files/2024-09/UI%20Field%20report%20154_Annual%20survey%20-%20regional%20view.pdf
69. Why PUE remains flat and what should be done about it. (n.d.). Upsite Technologies. https://www.upsite.com/blog/why-pue-remains-flat-and-what-should-be-done-about-it/